

Order No.: 1 06 048 (Z210060206)

PAVUS, a. s.

AUTORIZED BODY AO 216



FIRE TESTING LABORATORY VESELÍ NAD LUŽNICÍ

Accredited Testing Laboratory - accreditation issued by the Czech Accreditation Institute, o.p.s. Registered under Identification No. 1026

REACTION TO FIRE TEST REPORT

No. Pr-06-1.101-En

Issued on 2006-08-24

for product

Mesh Fabric

R 131 A101

Sponsor:

Saint-Gobain Vertex, s.r.o.

Sokolovská 106 570 21 Litomyšl

Test method:

EN ISO 1716

» Reaction to fire tests of building products

- Determination of the heat of combustion «

Report contains:

5 pages

(3 text pages + 2 annexes)

No. of copies: 3 Copy No.: 1

The report may not be reproduced other than in full, except with the written approval of testing laboratory.

Prosecká 412 / 74, 190 00 Praha 9 – Prosek, e-mail: mail@pavus.cz, http:// www.pavus.cz Company ID: 60193174, VAT payer ID: CZ60193174, in Company Register administerred by Municipal Court in Prague, section B. insert 2309

Tel.: +420 286 019 587, Fax: +420 286 019 590

Branch Veseli nad Lužnici

Čtvrť J. <u>Hybeše 879, 391 81 Veseli nad Lužnicí, e-mail: veseli@pavus.cz</u> Tel.: +420 381 581 128, +420 381 581 129, GSM gate: +420 603 296 301, Fax: +420 381 581 127



1 INTRODUCTION

The gross heat of combustion of homogenous building product has been determined following the order of company Saint-Gobain Vertex, s.r.o. in Fire Testing Laboratory of PAVUS, a.s. in Veselí nad Lužnicí.

The tests were prepared, performed and evaluated on the basis of following documents:

- [1] EN ISO 1716: Reaction to fire tests for building products Determination of the heat of combustion
- [2] EN 13238: Reaction to fire tests for building products Conditioning procedures and general rules for selection of substrates
- [3] Cover form of the product to be tested

For the purposes of this report the definitions stated in [1] and [2] are valid.

2 TEST SUBJECT

Product name:

R 131 A101

Product identification:

glass fibre mesh fabric

Manufacturer:

Saint-Gobain Vertex, s.r.o.

Sokolovská 106

570 21 Litomyšl

Product description:

R 131 A101 – glass fibre mesh fabric is used as a reinforcement

mass per unit area: 160 g/m²

organic content: 20 % thickness: 0,47 mm

surface treatment: alkali resistant

Date of sample arrival:

2006-05-12

Sampling procedure:

sponsor

Conditioning:

acc. to [2]

Test subjects were three specimens obtained by weighing of product, supplied by the sponsor.

3 TEST PERFORMANCE

Tests were performed according to [1] and [2].

The testing and measuring equipment used is given in Annex 1.

The tests were performed in the laboratory on the 13th June, 2006. The ambient air temperature was 21,0 °C with 54,7 % ambient air relative humidity.

The gross heat of combustion has been with all specimens determined by crucible method in adiabatic calorimeter.



4 TEST RESULTS

The gross heat of combustion of the specimen has been calculated from measured values, given in Annex 2.

Specimen	Gross heat of combustion <i>PCS</i> (MJ/kg)
1 06 027 / 1-3	8,27
1 06 027 / 2-3	8,10
1 06 027 / 3-3	8,12
Mean value	8,17

The gross heat of combustion of the specimen is 8,17 MJ/kg.

5 CONCLUSION

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Report and annexes sheets are valid with embossed stamp only.

Prepared by:

Ing. Lenka Horčičková Fire Testing Laboratory Engineer Approved by:

Ing. Mirko Louma

Assistant Manager of Fire Testing Laboratory



ANNEX 1: TESTING AND MEASURING EQUIPMENT, MEASUREMENT UNCERTAINTY

Test apparatus	Registration number
Adiabatic calorimeter IKA C4000	10.011
Pressure equipment	10.011

Measuring equipment	Metrological registration number
Thermo-hygro-baro-graph	3 13 08, 3 09 11
Digital balance KERN EW 6000	3 04 09
Analytical balance WAX 60/220	3 04 14

The metrological relationships of the device are defined in the metrological registration card of the device, this card is expressly identified by the metrological registration number of the device.

Measured quantity	Evended management up outsints			
Name	Symbol	Unit	Expanded measurement uncertainty	
Ambient air temperature	Τ	°C	< 0,7	
Calorimeter temperature	Q	°C	< 0,001	
Ambient air relative humidity	φ	%	< 2,6	
Water mass	m	g	< 0,12	
Specimen mass	m	g	< 0,0001	

The reported expanded uncertainties of measurement are stated as the standard uncertainties of measurement multiplied by the coverage factor k = 2, which for a normal distribution corresponds to a coverage probability of approximately 95 %.

The standard uncertainty of measurement has been determined in accordance with EA-16/02 and GUM.



ANNEX 2: MEASUREMENT

Component mass and temperature rise during the individual determination.

Specimen	Specimen mass (g)	Benzoic acid mass (g)	Cotton thread mass (g)	Temperature rise <i>ΔT</i> (K)
1 06 027 / 1-3	1,03139	-	0,03420	0,979
1 06 027 / 2-3	1,05587	-	0,03424	0,982
1 06 027 / 3-3	1,06711	-	0,03716	0,999

In all three cases a firing wire with 30 J gross heat of combustion has been used.

Calculation of the gross heat of combustion:

$$PCS = \frac{E(T_m - T_i + c) - b}{m}$$

Where:	
PCS gross heat of combustion	(MJ/kg)
E water equivalent of calorimeter with accessories (in this case 9,309·10 ⁻³)	(MJ/K)
T _i initial temperature	(K)
T _m maximum temperature	(K)
b correction to combustion supporting means	(MJ)
c temperature correction required for the exchange of heat with the outside (zero in this case)	(K)
m mass of the test specimen	(kg)

From the above expression the final values given in chapter 4 have been calculated.